

1. Q. What are the present constraints on the 138 kV system and planning options/system upgrades to mitigate and in what time frame? Are there any N-1 conditions that would trigger planned system upgrades.
 - A. Please refer to HECO's Solicitation of Interest, Section C, Information on Transmission Constraints Associated with Likely Areas of Interconnection. There are no N-1 conditions that would trigger planned system upgrades.