

Expanding Variability Limits with Generation

Presentation to HECO IRP Advisory Group



Hawaiian Electric Company, Inc.

1

Variability_Limits_r1.ppt

October 17, 2007

Agenda


- Background Information
- Assessing the Capabilities of Existing Generation
- “Tuning” Existing Infrastructure
- Potential for additional response in the future



Hawaiian Electric Company, Inc.

October 17, 2007

Getting More Non-Firm Renewables on the System (continued)



* As indicated by frequency and voltage fluctuations




Background Information

- Concepts previously discussed
 - Ramp rate
 - Voltage Regulation
 - Riding Through Disturbances
 - Droop Response



Firm Power: Ramp Rates



Oahu Generation System (excluding DG)

| Hawaiian Electric Company, Inc. | | | | | |
|---------------------------------|-----------------|--------------------|-----------------------------------|----------------------|----------|
| Unit | Capability (MW) | Type | Average Age as of: Operating Duty | 2007 In Service Date | Age (yr) |
| Honolulu 8 | 56 | Steam, Non-Reheat | Cycling | 1954 | 53 |
| Honolulu 9 | 57 | Steam, Non-Reheat | Cycling | 1957 | 50 |
| Waiau 3 | 49 | Steam, Non-Reheat | Cycling | 1947 | 60 |
| Waiau 4 | 49 | Steam, Non-Reheat | Cycling | 1950 | 57 |
| Waiau 5 | 57 | Steam, Non-Reheat | Cycling | 1959 | 48 |
| Waiau 6 | 56 | Steam, Non-Reheat | Cycling | 1961 | 46 |
| Waiau 7 | 92 | Steam, Reheat | Base Load | 1966 | 41 |
| Waiau 8 | 94 | Steam, Reheat | Base Load | 1968 | 39 |
| Waiau 9 | 53 | Combustion Turbine | Peaking | 1973 | 34 |
| Waiau 10 | 50 | Combustion Turbine | Peaking | 1973 | 34 |
| Kahe 1 | 92 | Steam, Reheat | Base Load | 1963 | 44 |
| Kahe 2 | 89 | Steam, Reheat | Base Load | 1964 | 43 |
| Kahe 3 | 92 | Steam, Reheat | Base Load | 1970 | 37 |
| Kahe 4 | 93 | Steam, Reheat | Base Load | 1972 | 35 |
| Kahe 5 | 142 | Steam, Reheat | Base Load | 1974 | 33 |
| Kahe 6 | 142 | Steam, Reheat | Base Load | 1981 | 26 |
| INDEPENDENT POWER PRODUCERS | | | | | |
| H-POWER | 46 | Steam, Non-Reheat | Base Load | 1990 | 17 |
| KPLP | 208 | Combined Cycle | Base Load | 1991 | 16 |
| AES | 180 | Steam, Reheat | Base Load | 1992 | 15 |
| TOTAL: | 1,697 | | | | |



System Frequency Control

Control of System Frequency is achieved by:

- Energy Management System
- Turbine Speed Control System (“Speed Governor”)



Turbine Speed Control

- All HECO generating units have Droop-type speed governors
- Control systems are always active
- Control system watches the turbine speed (or frequency) of the system
- Droop-type speed governors do not control to 60 Hz



Turbine Speed Governor

Normal Speed Control Setpoint = 3600rpm

Speed = 60 cycles/sec X 60 sec/minute
= 3600 cycles per minute
or 3600 revolutions/minute
(for a 2 pole generator)



Two Types of Speed Governor

- **Isochronous** – Provides 60 Hz under varying load conditions.
 - Maintains constant speed regardless of changes in load
 - Not used for systems of multiple units as the multiple units will not evenly share the load.
- **Droop** – Provides frequency stability under varying load conditions
 - Speed decreases or increases with change in load
 - Typically, the droop curve is 5% from 0% to full load
 - EMS/AGC adds correction to restore 60Hz.
 - Used on multi-units systems



Impact of Changing Load on a Generating Unit


- The Turbine Speed Governor is like the Cruise Control on a car going up Red Hill, trying to maintain turbine speed...
 - Starting up Red Hill (increase load) speed slows down. Must “feed more gas” to maintain a steady speed.
 - Going over the top of Red Hill (decrease load) speed increases. Must “let off the gas” to maintain a steady speed.

(Cruise Control would be an example of Isochronous Governor)




Turbine Speed Governor


The Turbine Speed Governor incrementally opens or closes steam flow control valves to add more steam or less steam, increasing or decreasing the generator output.




Steam-Electric Generating Unit Flow Diagram




Speed (Frequency) Response (Single Unit)




Speed (Frequency) Response (Single Unit – Load Increase)




Speed (Frequency) Response (Single Unit – Load Increase)




Speed (Frequency) Response (Single Unit – Load Decrease)



Speed Droop Curves



Speed (Frequency) Res (Multiple Units)



- System Load increases by 25MW
- Load increase will "split" between the 2 units
- Each unit "grabs" 12.5MW
- Frequency will settle at 59.6Hz

The opposite will occur if the load change was a DECREASE instead of an increase.



Energy Management System

Controls to a base frequency target of 60.000 Hz while economically balancing load across all units

- Units are dispatched via computer per Economic Cost Curves
- This process is occurring every 10 seconds



EMENS Spectrum Power TG


Unit Generation Limits Summary

| PLANT NAME | UNIT NAME | CONTROL STATUS | UNIT GENERATION MW | | | | UNIT GENERATION LIMITS MW | | | | | | DCE (MW) | PULSE SETPNT INDCTR | FREQUENCY CONTROL INDICATOR |
|------------|-----------|----------------|--------------------|---------|------------|---------|---------------------------|---------------|-------------|--------------|----------------|---------|----------|---------------------|-----------------------------|
| | | | ACTUAL | DESIRED | BASE POINT | OPTIMAL | MIN CAP | LFC/LOW PLANT | EDC/LOW EOC | EDC/HIGH EOC | LFC/HIGH PLANT | MAX CAP | | | |
| ONOLULU | HONO_8 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 24 m | 0 | 0 | 56 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| | HONO_9 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 25 m | 0 | 0 | 57 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| WIAU | WIAU_3 | ● UNAVAIL | 0 | 0 | 0 | 0 | 0 | 25 m | 0 | 0 | 49 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| | WIAU_4 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 24 m | 0 | 0 | 47 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| | WIAU_5 | ● AUTO | 26 | 26 | 25 | 25 | 0 | 25 m | 25 | 57 | 57 m | 57 | 0.5 | ▲ 0 | on_ctrl |
| | WIAU_6 | ● LOCAL | 15 | 15 | 15 | 17 | 0 | 25 m | 15 | 15 | 54 m | 15 | 0.0 | ▲ 0 | on_ctrl |
| | WIAU_7 | ● AUTO | 70 | 70 | 70 | 70 | 0 | 35 m | 35 | 87 | 87 m | 87 | -0.2 | ▲ 0 | on_ctrl |
| | WIAU_8 | ● AUTO | 42 | 42 | 42 | 44 | 0 | 35 m | 35 | 87 | 87 m | 87 | 0.1 | ▲ 0 | on_ctrl |
| | WIAU_9 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 5 m | 0 | 0 | 53 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| KANE | WIAU_10 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 5 m | 0 | 0 | 50 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| | KANE_1 | ● AUTO | 76 | 76 | 76 | 77 | 0 | 38 | 38 | 86 | 86 m | 86 | -0.0 | ▲ 0 | on_ctrl |
| | KANE_2 | ● AUTO | 68 | 68 | 68 | 75 | 0 | 38 | 38 | 86 | 86 m | 86 | 0.3 | ▲ 0 | on_ctrl |
| | KANE_3 | ● AUTO | 71 | 71 | 70 | 71 | 0 | 38 m | 38 | 90 | 90 m | 90 | 0.3 | ▲ 0 | on_ctrl |
| | KANE_4 | ● AUTO | 78 | 78 | 78 | 78 | 0 | 40 m | 40 | 85 | 85 m | 85 | 0.3 | ▲ 0 | on_ctrl |
| | KANE_5 | ● LOCAL | 135 | 135 | 135 | 129 | 0 | 60 m | 60 | 142 | 142 m | 142 | 0.0 | ▲ 0 | on_ctrl |
| KANE_6 | ● AUTO | 139 | 142 | 142 | 142 | 0 | 60 m | 60 | 142 | 142 m | 142 | 2.6 | ▲ 1 | on_ctrl | |
| | ● AUTO | | | | | | | | | | | | | | |
| KALAEOA | KALA_1 | ● AVAIL | 0 | 0 | 0 | 0 | 0 | 60 m | 0 | 0 | 104 m | 0 | 0.0 | ▲ 0 | on_ctrl |
| | KALA_2 | ● MANU | 99 | 99 | 99 | 90 | 0 | 60 m | 60 | 90 | 104 m | 90 | 0.0 | ▲ 0 | on_ctrl |
| RRV | RRRV | ● LOCAL | 21 | 21 | 21 | 21 | 0 | 20 m | 21 | 21 | 46 m | 21 | 0.0 | ▲ 0 | on_ctrl |
| ES | AES | ● LOCAL | 86 | 86 | 86 | 90 | 0 | 60 m | 60 | 90 | 90 m | 90 | 0.0 | ▲ 0 | on_ctrl |

Discussions not available on http://172.30.28.51/

Generator Control Panel





“Tuning” Existing Infrastructure

- Tuning of generators and controls to provide increased response [*tuning of boiler and turbine controls, governor controls*]
- Tuning of Automatic Generator Controls to provide increased system response [*tuning of AGC*]
- Coordination of generator controls and AGC [*coordination between the EMS and plants*]
- Changes in operational practices [*including mix of online generation, regulating reserve/QLPU levels, etc.*]



Tuning of generators and controls to provide increased response

- Environmental Compliance
- Operating the generating unit in a safe manner to ensure operational longevity
 - Metal Temperature Limits
- Operating the unit efficiently
 - Production Costs



Tuning of AGC to provide increased system response

- 10 second cycle control pulse
 - Could look into shorter control cycles
 - Need to assess the impact on the system stability
- Ramp Rate Testing
 - HECO currently testing existing ramp rates (explained earlier)
- Understanding how the generating units are accepting the EMS pulses



Coordination of generator controls and AGC

- Coordination of all inputs
 - AGC 10 second pulse cycle under normal frequency conditions
 - Unit's droop response (Quick Load Pickup)



Changes in operational practices

- Current Spinning Reserve: Largest unit
 - 180 MW with AES, 142 MW with K5 or K6
- QLPU: Loss of K5 or K6
- Current Unit Commitment: Based on Economics
- Current Unit Dispatch: Based on Economics




Changes in operational practices (cont)

- Increasing Spinning Reserve and QLPU Requirements to mitigate fluctuation rates
 - Equates to turning on the next cycling unit earlier
 - Equates to turning on another unit that could have stayed off-line


Cost of Generating Electricity Increases



Changes in operational practices How units are dispatched today



Changes in operational practices Non-economic dispatch



Questions?

